

## Water Testing Results - Madras Elementary

### Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Madras Elementary	MA Health Room DF	1/20/2017	3 ppb
Madras Elementary	MA Cafeteria DF	1/20/2017	ND
Madras Elementary	MA Hallway West DF	1/20/2017	ND
Madras Elementary	MA Room 3	1/20/2017	ND
Madras Elementary	MA Room 4	1/20/2017	ND
Madras Elementary	MA Room 5	1/20/2017	ND
Madras Elementary	MA Room 6	1/20/2017	ND
Madras Elementary	MA Room 7	1/20/2017	ND
Madras Elementary	MA Room 8	1/20/2017	ND
Madras Elementary	MA Room 9	1/20/2017	ND
Madras Elementary	MA Room 10	1/20/2017	ND
Madras Elementary	MA Room 11	1/20/2017	ND
Madras Elementary	MA Room 12	1/20/2017	ND
Madras Elementary	MA Room 13	1/20/2017	ND
Madras Elementary	MA Room 14	1/20/2017	ND
Madras Elementary	MA Room 15	1/20/2017	ND
Madras Elementary	MA Room 16	1/20/2017	ND
Madras Elementary	MA Room 17	1/20/2017	ND
Madras Elementary	MA Room 18	1/20/2017	ND
Madras Elementary	MA Room 19	1/20/2017	ND
Madras Elementary	MA Room 20	1/20/2017	ND
Madras Elementary	MA Room 21	1/20/2017	ND
Madras Elementary	MA Gym Hall	1/20/2017	ND
Madras Elementary	MA Hallway Rm 17	1/20/2017	ND
Madras Elementary	MA Room 23	1/20/2017	ND
Madras Elementary	MA Room 24	1/20/2017	ND
Madras Elementary	MA Hallway Rm 5	1/20/2017	ND
Madras Elementary	MA Hallway Rm 8	1/20/2017	ND
Madras Elementary	Staff Breakroom Sink/Food Prep	1/20/2017	ND
Madras Elementary	MA Hallway Library	1/20/2017	ND
Madras Elementary	MA Gym	1/20/2017	ND
Madras Elementary	MA Room 22	1/20/2017	ND
Madras Elementary	MA Staff Rm	1/20/2017	ND
Madras Elementary	MA Kitchen	1/21/2017	ND