Water Testing Results - Madras High School Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Madras High School	MHS Boys Locker Rm 1	12/29/2016	ND
Madras High School	MHS Boys Locker Rm 2	12/29/2016	ND
Madras High School	MHS Girls Locker Rm	12/29/2016	ND
Madras High School	MHS Kitchen	12/29/2016	ND
Madras High School	MhS Gym	12/29/2016	ND
Madras High School	MHS Weight Rm	12/29/2016	ND
Madras High School	MhS Construction Shop	12/29/2016	ND
Madras High School	Band/Drinking Fountain	12/29/2016	ND
Madras High School	MhS Manufacturing	12/29/2016	12 ppb
Madras High School	MHS Training Lab	12/29/2016	ND
Madras High School	MHS Tech Office	12/29/2016	ND
Madras High School	MHS Band	12/29/2016	ND
Madras High School	MHS Choir	12/29/2016	ND
Madras High School	MHS Office Staff Rm	12/29/2016	ND
Madras High School	MHS Student Services Office	12/29/2016	ND
Madras High School	MHS Fresh Hall DF	12/29/2016	ND
Madras High School	MHS Soph DF	12/29/2016	ND
Madras High School	MHS Rm 7 DF	12/29/2016	ND
Madras High School	MHS Hall B105 DF	12/29/2016	ND
Madras High School	MHS Hall B106 DF	12/29/2016	ND
Madras High School	MHS Hall B107 DF	12/29/2016	ND
Madras High School	MHS Hall by Rm 25	12/29/2016	ND
Madras High School	MHS Rm 27	12/29/2016	ND
Madras High School	MHS Rm 28	12/29/2016	ND
Madras High School	MHS Rm 30	12/29/2016	ND
Madras High School	MHS Rm 33	12/29/2016	ND
Madras High School	MHS Rm 46	12/29/2016	ND
Madras High School	MHS Rm 45	12/29/2016	ND
Madras High School	MHS Wrestling Rm	12/29/2016	ND
Madras High School	MHS Hall by Rm 48	12/29/2016	ND
Madras High School	MHS Hall by Gym	12/29/2016	ND