

**Water Testing Results - Bridges**  
**Action Level is 15 parts per billion (ppb)**

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Bridges High School	Bridges FP	1/20/2017	ND
Bridges High School	Hall by 5	1/20/2017	ND
Bridges High School	Office	1/20/2017	ND
Bridges High School	TC Sink	1/20/2017	ND
Bridges High School	Computer Lab DF	1/20/2017	2 ppb
Bridges High School	Gym	1/20/2017	ND
Bridges High School	Upper Gym	1/20/2017	ND