

Water Testing Results - (JCMS) Jefferson County Middle School

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
JCMS	JCMS DF by Hall Comp Lab	1/20/2017	ND
JCMS	JCMS Hall Science	1/20/2017	ND
JCMS	JCMS Hall by Rm 24	1/20/2017	ND
JCMS	JCMS Staff	1/20/2017	2 ppb
JCMS	JCMS Hall 130	1/20/2017	ND
JCMS	JCMS DF Girls Locker	1/20/2017	ND
JCMS	JCMS DF Rm 232	1/20/2017	ND
JCMS	JCMS Hall 212	1/20/2017	ND
JCMS	JCMS Commons	1/20/2017	ND
JCMS	JCMS DF Rm 220	1/20/2017	ND
JCMS	JCMS Hall Life Skills	1/23/2017	ND
JCMS	JCMS DF Boys Locker	1/23/2017	ND