Jefferson School District
District-Wide Card Access Control Site Survey Questions

Q. You have alarm system keypads and door contacts going to alarm on the plans, but no alarms in specifications – are alarm systems needed for this bid?
A. No

Q. Do you need Request to Exit (REX)?
A. No

Q. Security cameras are listed on plans – is this bid for security cameras?
A. No

Q. In the specifications there is door hardware schedule mentioned, but not has been provided? Is electromechanical hardware already existing or being provided? Is it included within the scope for this bid?
A. Most doors have existing hardware. There are several new doors that need hardware. Hardware standards are Von Duprin and Best.

Q. Are all the buildings on a shared network?
A. Yes

Q. PDK & Avigilon are listed as approved systems, but there are significant difference between them. Are you looking for more affordability or larger feature set?
A. Looking to see pricing for both.

Q. PDK does not technically meet the fine print specifications (such as storing data at each controller locally in the event of comms loss), but is approved – how do you expect us to rectify this conflict?
A. As approved systems, we understand there are slight nuisances but they are approved as acceptable for all intensive purposes.

Q. Do you have a preference on which software platform based on demonstrations?
A. No

Q. For PDK they have wireless network transmission vs hardwired door controllers. Do you want to use those to save network installation costs? Or do you want all the controllers hardwired to the network?
A. Hardwired

Q. Do you have an estimated budget for this project?
A. No formal estimate has been provided.