



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/14/2022
Received: 02/01/2022
Sampled By: Charles Spear
Work Order: 2033002

C Environmental Inspection Services
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project:
Project # : -
Sample Type :
PO # : 2021096

Sampling Location: Maintenance Shop/ Transportation/ Food

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2033002-01	Sample Name: 20530003 BF 098 22A Sampled: 1/28/22 11:20						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/08/22 15:24
2033002-02	Sample Name: 20530003 SF 099 22A Sampled: 1/28/22 11:21						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/08/22 15:24
2033002-03	Sample Name: 20530003 SF 100 22A (lounge) Sampled: 1/28/22 11:23						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/08/22 15:24
2033002-04	Sample Name: 20530002 SF 101 22A (food) Sampled: 1/28/22 11:24						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/08/22 15:24
2033002-05	Sample Name: 20530004 DW 102 22A shop Sampled: 1/28/22 11:25						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/08/22 15:24
2033002-06	Sample Name: 20530001 SF 103 22A (trans) Sampled: 1/28/22 11:26						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/08/22 15:24
2033002-07	Sample Name: 20530001 DW 104 22A Sampled: 1/28/22 11:27						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/08/22 15:24
2033002-08	Sample Name: 20530001 SF 105 22A Sampled: 1/28/22 11:28						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/08/22 15:24
2033002-09	Sample Name: 20530001 BF 106 22A Sampled: 1/28/22 11:29						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/08/22 15:24
2033002-10	Sample Name: 20530001 BF 107 22A Sampled: 1/28/22 11:30						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/08/22 15:24



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/14/2022
Received: 02/01/2022
Sampled By: Charles Spear
Work Order: 2033002

CLIENT Environmental Inspection Services

Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project:

Project # : -
Sample Type :
PO # : 2021096

Sampling Location: Maintenance Shop/ Transportation/ Food

Lab Number

ND = None detected at the MRL MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by:

[Handwritten signature of Adriana Gonzalez-Gray]

Adriana Gonzalez-Gray
Laboratory Director