



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 02/14/2022  
Received: 02/01/2022  
Sampled By: Charles Spear  
Work Order: 2032019

**C** Environmental Inspection Services  
**L**  
**I** Attn: Charles Spear  
**E** 11981 Fargo Rd  
**N** Aurora OR, 97002  
**T** Phone: (503) 680-6398

**Project:** Performing Arts  
Project # : -  
Sample Type : Grab  
PO # : 2021096

Sampling Location: 412 SE Buff Street Madras, OR 97741

**Lab Number**

|                   | Code  | Method    | Result                                | Units | MRL | EPA MCL* | Analysis Date/ Time           |
|-------------------|---|-----------|---------------------------------------|-------|-----|----------|-------------------------------|
| <b>2032019-01</b> | <b>Sample Name:</b> 20530501 001 BF 001 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:15                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-02</b> | <b>Sample Name:</b> 20530501 002 BF 002 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:15                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-03</b> | <b>Sample Name:</b> 20530501 003 BF 003 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:15                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-04</b> | <b>Sample Name:</b> 20530501 004 DW 004 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:16                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-05</b> | <b>Sample Name:</b> 20530501 005 DW 005 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:16                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-06</b> | <b>Sample Name:</b> 20530501 006 BF 006 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:16                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-07</b> | <b>Sample Name:</b> 20530501 007 BF 007 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:17                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-08</b> | <b>Sample Name:</b> 20530501 008 BF 008 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:17                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-09</b> | <b>Sample Name:</b> 20530501 009 BF 009 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:17                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-10</b> | <b>Sample Name:</b> 20530501 010 BF 010 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:18                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 02/14/2022  
Received: 02/01/2022  
Sampled By: Charles Spear  
Work Order: 2032019

**C** Environmental Inspection Services  
**L** Attn: Charles Spear  
**I** 11981 Fargo Rd  
**E** Aurora OR, 97002  
**N** Phone: (503) 680-6398  
**T**

**Project:** Performing Arts  
Project # : -  
Sample Type : Grab  
PO # : 2021096

Sampling Location: 412 SE Buff Street Madras, OR 97741

**Lab Number**

|                   | Code  | Method    | Result                                | Units | MRL | EPA MCL* | Analysis Date/ Time           |
|-------------------|---|-----------|---------------------------------------|-------|-----|----------|-------------------------------|
| <b>2032019-11</b> | <b>Sample Name:</b> 20530501 011 CF 011 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:30                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | 1                                     | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-12</b> | <b>Sample Name:</b> 20530501 012 CF 012 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:30                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-13</b> | <b>Sample Name:</b> 20530501 013 CF 013 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:31                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-14</b> | <b>Sample Name:</b> 20530501 014 DW 014 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:35                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-15</b> | <b>Sample Name:</b> 20530501 015 DW 015 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:36                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-16</b> | <b>Sample Name:</b> 20530501 016 BF 016 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:37                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-17</b> | <b>Sample Name:</b> 20530501 017 DW 017 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:42                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-18</b> | <b>Sample Name:</b> 20530501 018 DW 018 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:42                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-19</b> | <b>Sample Name:</b> 20530501 019 BF 019 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:43                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-20</b> | <b>Sample Name:</b> 20530501 020 BF 020 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:45                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 02/14/2022  
Received: 02/01/2022  
Sampled By: Charles Spear  
Work Order: 2032019

**C** Environmental Inspection Services  
**L**  
**I** Attn: Charles Spear  
**E** 11981 Fargo Rd  
**N** Aurora OR, 97002  
**T** Phone: (503) 680-6398

**Project:** Performing Arts  
Project # : -  
Sample Type : Grab  
PO # : 2021096

Sampling Location: 412 SE Buff Street Madras, OR 97741

**Lab Number**

|                   | Code  | Method    | Result                                | Units | MRL | EPA MCL* | Analysis Date/ Time           |
|-------------------|---|-----------|---------------------------------------|-------|-----|----------|-------------------------------|
| <b>2032019-21</b> | <b>Sample Name:</b> 20530501 021 BF 021 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:45                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-22</b> | <b>Sample Name:</b> 20530501 022 BF 022 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:46                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-23</b> | <b>Sample Name:</b> 20530501 023 BF 023 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:47                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-24</b> | <b>Sample Name:</b> 20530501 024 DW 024 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:48                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-25</b> | <b>Sample Name:</b> 20530501 025 DW 025 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:48                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-26</b> | <b>Sample Name:</b> 20530501 026 BF 026 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:49                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-27</b> | <b>Sample Name:</b> 20530501 027 BF 027 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:50                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-28</b> | <b>Sample Name:</b> 20530501 028 BF 028 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:51                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-29</b> | <b>Sample Name:</b> 20530501 029 BF 029 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:52                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | ND                                    | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |
| <b>2032019-30</b> | <b>Sample Name:</b> 20530501 030 BF 030 22A |           |                                       |       |     |          | <b>Matrix:</b> Drinking Water |
|                   | <b>Sampled:</b> 1/28/22 8:55                |           | <b>Sample Composition:</b> Raw Single |       |     |          |                               |
| †Lead             | 1030  | EPA 200.9 | 6                                     | ppb   | 1   | 15 ppb   | 02/07/22 13:47                |



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/14/2022
Received: 02/01/2022
Sampled By: Charles Spear
Work Order: 2032019

C
L
I
E
N
T

Environmental Inspection Services

Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: Performing Arts

Project #: -
Sample Type: Grab
PO #: 2021096

Sampling Location: 412 SE Buff Street Madras, OR 97741

Lab Number

Table with 8 columns: Lab Number, Code, Method, Result, Units, MRL, EPA MCL\*, Analysis Date/ Time. Contains three rows of data for samples 2032019-31, 2032019-32, and 2032019-33.

ND = None detected at the MRL MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by:

Handwritten signature of Adriana Gonzalez-Gray

Adriana Gonzalez-Gray
Laboratory Director